

شهادة اعتماد

رقم IB 016



بقر نظام الاعتماد العراقي بأن:
شركة الامارات العربية للتجارة العامة ونصب وتجهيز وصيانة أنظمة
اطفاء الحرائق و الانذار المبكر محدودة المسؤولية
العراق - بغداد - المنصور - البيجية

تم اعتمادها وفقا لمتطلبات المواصفة ISO/ IEC 17020:2012
(Conformity assessment - Requirements for the operation of various types of bodies performing inspection)
TYPE - C-

في مجال:

- قطاع أنظمة اطفاء الحريق
- قطاع منظومات الكشف والانذار بالحريق
- قطاع الحماية من الحريق
- قطاع المراحل الحرارية
- قطاع الانشاءات
- قطاع معدات الرفع
- قطاع الخزانات

شرط التوافق مع متطلبات المواصفة اعلاه ومتطلبات IQAS الخاصة بالاعتماد
مجال الاعتماد المرفق بالشهادة يعتبر جزءا لا يتجزء منها
يمكن الحصول على الاصدار الاحدث من مجال الاعتماد من خلال الموقع الالكتروني

<https://iqas.mop.gov.iq>

يكون الاعتماد نافذا من ٢٠٢٤/٧/٢١ الى ٢٠٢٦/٧/٢٠
تاريخ منح الاعتماد لأول مرة
٢٠٢٢/٦/٢٦

أ.د. محمد علي تميم
نائب رئيس مجلس الوزراء
وزير التخطيط

د. محمد لطيف أحمد
مدير عام الهيئة العراقية للاعتماد

ACCREDITATION CERTIFICATE

No. IB 016



Iraqi Accreditation System Certify that:

**Arab Emirates Company for General Trading, Set Up,
Preparation and Maintaining Firefighting and Fire Alarm
Systems, Limited Liability**

Iraq- Baghdad – Al-Mansur – Al-Bajeea

Is accredited according to the requirements of the standard ISO/IEC 17020:2012
(Conformity assessment requirements for the operation of various types of bodies performing inspection)

TYPE - C –

In the field of:

- Firefighting Sector - Fire Alarm and Detection System Sector
- Fire Protection Sector - Fired Boilers Sector
- Structure Sector - Lifting Equipment Sector - Tanks Sector

This accreditation is subject to with the above standard & IQAS requirements
The scope of accreditation is attached to the certificate & considered as part of it

The most recent issue of the accreditation scope is available on IQAS website

<https://iqas.mop.gov.iq>

Accreditation is valid From 21/7/2024 To 20/7/2026

Initial accreditation date


26/6/2022

Dr. Mohammed Lateef Ahmed
General Manager of IQAS

Dr. Mohammed Ali Tamim
Deputy Prime Minister
Minister of Planning

	استمارة مجال الاعتماد Scope of Accreditation form	نظام الاعتماد العراقي IQAS
Organization address: Iraq- Baghdad – Al-Mansur – Al-Bajeea	Organization name : Arab Emirates Company for General Trading, Set Up, Preparation and Maintaining Firefighting and Fire Alarm Systems, Limited Liability	Accreditation no.: IB 016
Signature: Abdul Wahid Mohammed Ibrahim Deputy General Manager	Accreditation is valid: From 21/7/2024 To 20/7/2026	Issue no. : 003

Inspection field	Materials / Products	Type of Inspection	Reference to standardized method
Fire extinguishers check	CO ₂ / Foam / Powder	Periodic every six months	NFPA10:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Fire nozzles check	Fire nozzle are practically checked	Periodic every six months	NFPA14:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Fire alarm check	Practical examination of fire alarms	Periodic every six months	NFPA72:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Cabinet check	Cabin is practice	Periodic every six months	NFPA14:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Inspection of cabin internal crack and safety	Inspection of the cabin internal crack practically	Periodic every six months	NFPA20:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Diesel fire pump check	Inspect the fire pump in practice	Periodic every six months	NFPA20:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Electric fire pump check	Inspect the fire pump in practice	Periodic every six months	NFPA20:2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع
Inspection of the jockey fire system	Checking the fire jockey fire system	Periodic every six months	NFPA20:E2019 Iraqi building code 405 م.ب.ع Iraqi building code 405/3 م.ب.ع Iraqi building code 405/4 م.ب.ع

	استمارة مجال الاعتماد Scope of Accreditation form	نظام الاعتماد العراقي IQAS
Organization address: Iraq- Baghdad – Al-Mansur – Al-Bajeea	Organization name : Arab Emirates Company for General Trading, Set Up, Preparation and Maintaining Firefighting and Fire Alarm Systems, Limited Liability	Accreditation no.: IB 016
Signature:  Abdul Wahid Mohammed Ibrahim Deputy General Manager	Accreditation is valid: From 21/7/2024 To 20/7/2026	Issue no. : 003

Co2 system check	Co2 fire system check	Periodic every six months	NFPA12: 2019 Iraqi building code 405 م.ب.ع. Iraqi building code 405/3 م.ب.ع. Iraqi building code 405/4 م.ب.ع.
FM 200 system check	FM 200 fire system check	Periodic every six months	NFPA2001: 2019 Iraqi building code 405 م.ب.ع. Iraqi building code 405/3 م.ب.ع. Iraqi building code 405/4 م.ب.ع.
Foam system check	Inspection of the fire foam system	Periodic every six months	NFPA11: 2019 Iraqi building code 405 م.ب.ع. Iraqi building code 405/3 م.ب.ع. Iraqi building code 405/4 م.ب.ع.
Drawing	Drawing fire alarm system / fire fighting	Before and after execution	Iraqi building code 405 م.ب.ع. Iraqi building code 405/3 م.ب.ع. Iraqi building code 405/4 م.ب.ع. NFPA10:2019, NFPA11:2019 NFPA12:2019, NFPA13:2019 NFPA16:2019, NFPA17:2019 NFPA20:2019, NFPA22:2019 NFPA24:2019, NFPA72:2019 NFPA101:2019, NFPA2001:2019
Lifting equipment inspection	Elevator/lift	Periodic and thorough inspection	Iraqi building code 403:2014 BS EN 81-72 BS 7121-2-1 BS 7121-2-3
Reaction fire test for products	Building products	Periodic and thorough inspection	ISO 1182:2020
Inspection of fire boiler	All material components	Periodic and thorough inspection	API 573:2013
Inspection of tank	All material components	Periodic and thorough inspection	API 653:2020